



State of Utah

JON M. HUNTSMAN, JR.  
Governor

GARY R. HERBERT  
Lieutenant Governor

## Department of Administrative Services

KIMBERLY K. HOOD  
Executive Director

### Division of Facilities Construction and Management

F. KEITH STEPAN  
Director

# ADDENDUM #1

Date: February 12, 2007

To: Contractors

From: Craig Wessman, Project Manager, DFCM

Reference: Salt Lake Community College  
Chiller Removal – Business and Technology Building  
DFCM Project No. 06165660

Subject: **Addendum No. 1**

Pages	Addendum	1	page
	<u>Engineers Addendum No. 1</u>	<u>1</u>	<u>page</u>
	<b>Total</b>	<b>2</b>	<b>pages</b>

---

***Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.***

**2.1 SCHEDULE CHANGES – There are no project schedule changes per this Addendum.**

**2.2 GENERAL – See attached documents  
Van Boerum & Frank Associate, Addendum No. 1**

**End of Addendum #1**

February 12, 2007

Chiller Removal – Business and Technology Buildings  
Salt Lake Community college  
Redwood Road Campus  
Salt Lake City, Utah

DFCM Project No. 06165660

J. Howard Van Boerum, P.E.  
John D. Frank, P.E.  
Kim P. Harris, P.E.  
David P. Baranowski, P.E.  
Richard G. Reeder, P.E.  
Joseph V. Simmons, P.E.  
Byron R. Torgersen, P.E.  
Jeffrey S. Watkins, P.E.  
Donald K. Bradshaw, P.E.  
Benjamin L. Davis, P.E.  
Ladd M. Birch, P.E.  
Michael S. Mooney  
Neil H. Spencer, P.E.  
Wade W. Bennion, P.E.  
Steven T. Shepherd, P.E.

#### **Addendum No. 1**

1. Refer to Drawing M-101 Keyed Note No. 1. The Lithium Bromide will be removed by the Owner.
2. Refer to Drawing M-102 Keyed Note No. 9. The R-11 Refrigerant will be removed by the Owner.
3. Refer to the drawings and specifications. The abandoned pipes shall be labeled "ABANDONED PIPE," adjacent to the pipe cap.
4. Refer to Drawing M-101. Where the two 8" condenser water pipe are capped going into the tunnel, the two shutoff valves shall be salvaged to the Owner.
5. Refer to Drawing M-102, Detail D1 "Cooling Tower Enclosure." Provide (2) 4'-0" wide gates on the East side of the enclosure.